



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Taluk Level Water Quality testing laboratory, Sub Division Koppa

Criteria: NABL 139,
Certificate Number : NABL -DWT-00948

Email ID: rdwsw.wqmosp.koppa@gmail.com

TEST REPORT					
Taluk: Grama Panchayath: DCMC High School Village: Habitation: HILUVALLI Location of Source: Name: PDO Contact Number:				Report date: 02/05/2025 Reference: Sample receipt Form Sample receipt date: Date of Sample collection: 28/05/2025 Analysis start date: 29/05/2025 Analysis completion date: 29/05/2025 Sample collection protocol: APHA Method	
Sample Particulars:				Sample quantity: 1litter	
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Clear Colourless Liquid					
1.	pH Value @25°C	6.69	6.5-8.5	No relaxation	IS 3025 (Part-11) :2022
2.	Specific Conductance, µS/cm@25°C	—	—	—	IS 3025 (Part-14) :2013
3.	Odour	Appreciable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Taste	Appreciable	Agreeable	Agreeable	IS 3025 (Part-8):2017
5.	Colour, CU	1	5	15	IS 3025 (Part-4) :2021
6.	Turbidity, NTU	—	1	5	IS 3025 (Part-10) : 1984
7.	Total Dissolved Solids @ 105°C, mg/L	329	500	2000	IS 3025 (Part-16) : 1984
8.	Alkalinity as CaCO ₃ , mg/L	196	200	600	IS 3025 (Part-23) : 1986
9.	Total Hardness as CaCO ₃ , mg/L	187.8	200	600	IS 3025 (Part-21) : 2009
10.	Calcium as Ca, mg/L	22.8	75	200	IS 3025 (Part-40) : 1991
11.	Magnesium as Mg, mg/L	2.68	30	100	IS 3025 (Part-46) : 1994
12.	Chloride as Cl, mg/L	26.62	250	1000	IS 3025 (Part-32) : 1988
13.	Sulphate as SO ₄ , mg/L	—	200	400	IS 3025 (Part-24) : 2022
14.	Fluoride as F, mg/L	—	1	1.5	APHA 23 rd Edition
15.	Nitrate as NO ₃ , mg/L	—	45	No relaxation	APHA 23 rd Edition
16.	Iron as Fe, mg/L	—	1	No relaxation	IS 3025 (Part-53) : 2003
Remarks: The above tested parameters Compliance with the Specification of IS 10500 : 2012 RA:2018 Drinking Water Specification.					
Analysed by: Apoorva B S Analyst			Verified by: Assistant executive engineer		

Disclaimer:

- 1) The result apply to the sample as received..
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Samples will be discarded after 15 days from the date of report generation.
- 4) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

Secretary
D.C.M.C. HIGH SCHOOL
AFF No. 830780
(Affiliated to CBSE DEHLI)

Principal
D.C.M.C. High School-AFF 830780
Hiluvalli Village, N.R Pura

RDWSD/WQMSP/TeR/01
Assistant Executive Engi
Rural Drinking Water Supply & Sai
Subdivision, Koppa - 577121

Annexure C

PROFARMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:29-04-2025

It is certified that an inspection team headed by RURAL DRINKING WATER & SANITATION DEPARTMENT,GoK, Taluk level Water Quality Testing laboratory, Sub Division, Koppa From. Koppa Sub Division PHED inspected the DCMC HIGH SCHOOL, Hiluvalli Village, Narasimharajapura Taluk o 02/05/2025 and on the basis of Koppa Sub division PHED Lab certified that the DCMC HIGH SCHOOL,Hiluvalli Village,Narasimharajapura has safe drinking water facilities for the students and member of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T.Govt.

This certificate is valid till:29-11-2025



Specialist
Taluk General Hospital
Narasimharajapura-577 134
Chikkamagaluru Dist.

Signature with Seal

To.

Principal
DCMC High School
Hiluvalli Villege,
Narasimharajapura Taluk


Secretary
D.C.M.C. HIGH SCHOOL
AFF No. 830780
(Affiliated to CBSE DEHLI)


Principal
D.C.M.C. High School-AFF 830780
Hiluvalli Village, N.R Pura